

I'd like to see some way of helping consumers compare the dehumidification performance of air conditioners. It's hard to find information on the Sensible Heat Ratio (SHR) of new air conditioners, which would help consumers make an informed choice. In humid climates, controlling summer humidity is sometimes a challenge with typical air conditioning equipment.

For more information on this problem, see:

<http://www.cibse.org/pdfs/3dhenderson.pdf>

My employer, Madison Gas and Electric Company didn't review this comment. It's my opinion based on conversations with customers.

Jonathan Beers
Residential Services Manager
Madison Gas and Electric Company
P.O. Box 1231
Madison, WI 53701-1231